

Don & Low Ltd Nonwovens

Glamis Road

Forfar

Angus DD8 1EY

Tel: 01307 452600 Fax: 01307 452610

e-mail: nonwovens@donlow.co.uk

website: www.donlow.co.uk

Agrément Certificate

No 05/4221

PRODUCT SHEET 1 — DALTEX MULTITX BARRIER ROOF TILE UNDERLAY

PRODUCT SCOPE AND SUMMARY OF CERTIFICATE

This Certificate relates to the Daltex MultiTX Barrier Roof Tile Underlay for use in tiled and slated ventilated pitched roofs in unsupported applications.

THIS CERTIFICATE INCLUDES:

- factors relating to compliance with UK Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.



KEY FACTORS ASSESSED

Weathertightness — as part of a complete roof, the product will resist the passage of water and wind-blown snow and dust into the interior of the building (see section 4).

Wind loading — when installed on appropriately spaced battens the product's physical properties are deemed adequate to resist the wind loads imposed on the underlay. The product will reduce the wind uplift forces acting on the roof covering (see section 6).

Strength — the product has adequate strength to resist the loads associated with the installation of the roof (see section 7).

Durability — under the normal conditions found in a roof space the product will have a service life comparable to a traditional roof tile underlay (see section 9).

The BBA has awarded this Agrément Certificate for the Daltex MultiTX Barrier Roof Tile Underlay to Don & Low Ltd Nonwovens as fit for its intended use provided it is installed, used and maintained as set out in this Agrément Certificate.

On behalf of the British Board of Agrément

Date of First issue: 29 April 2005

Date of Second issue: 23 May 2007



Greg Cooper: Chief Executive

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity of this Agrément Certificate by either referring to the BBA's website (www.bbacerts.co.uk) or contacting the BBA direct.

Regulations

In the opinion of the BBA, the Daltex MultiTX Barrier Roof Tile Underlay, if used in accordance with the provisions of this Certificate, will meet or contribute to meeting the relevant requirements of the following Building Regulations:



The Building Regulations 2000 (as amended) (England and Wales)

Requirement:	C2(b)	Resistance to moisture
Comment:		The product will contribute to a roof meeting this Requirement. See sections 4.1 and 4.2 of this Certificate.
Requirement:	Regulation 7	Materials and workmanship
Comment:		The product is an acceptable material. See section 9 of this Certificate.



The Building (Scotland) Regulations 2004 (as amended)

Regulation:	8	Fitness and durability of materials and workmanship
Regulation:	8(1)	Fitness and durability of materials and workmanship
Comment:		The product can contribute to a construction satisfying this Regulation. See section 9 and the <i>Installation</i> part of this Certificate.
Regulation:	9	Building standards – construction
Standard:	3.10	Precipitation
Comment:		The product will contribute to a roof satisfying clauses 3.10.1 ⁽¹⁾⁽²⁾ and 3.10.7 ⁽¹⁾⁽²⁾ of this Standard. See sections 4.1 and 4.2 of this Certificate.
Regulation:	12	Building standards – conversions
Comment:		All comments given for this product under Regulation 9, also apply to this Regulation, with reference to clause 0.12.1 ⁽¹⁾⁽²⁾ and Schedule 6 ⁽¹⁾⁽²⁾ . (1) Technical Handbook (Domestic). (2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2000 (as amended)

Regulation:	B2	Fitness of materials and workmanship
Comment:		The product is an acceptable material. See section 9 of this Certificate.
Regulation:	C4(b)	Resistance to ground moisture and weather
Comment:		The product will contribute to a roof satisfying this Regulation. See sections 4.1 and 4.2 of this Certificate.

Construction (Design and Management) Regulations 2007

Construction (Design and Management) Regulations (Northern Ireland) 1995 (as amended)

Information in this Certificate may assist the client, CDM co-ordinator or planning supervisor, designer and contractors to address their obligations under these Regulations.

See section: 1 *Description* (1.2).

Non-regulatory Information

NHBC Standards 2006

NHBC accepts the use of the Daltex MultiTX Barrier Roof Tile Underlay, when installed and used in accordance with this Certificate, in relation to NHBC Standards, Chapter 7.2 *Pitched roofs*.

Zurich Building Guarantee Technical Manual 2007

In the opinion of the BBA, the Daltex MultiTX Barrier Roof Tile Underlay, when installed and used in accordance with this Certificate, satisfies the requirements of the *Zurich Building Guarantee Technical Manual*, Section 4 *Superstructure*, Sub-section *Pitched roofs*.

General

This Certificate relates to the Daltex MultiTX⁽¹⁾ Barrier Roof Tile Underlay for use in tiled or slated ventilated pitched roofs in accordance with the relevant clauses of BS 5534 : 2003.

The product will also prevent the ingress of wind-blown rain or snow.

(1) Daltex MultiTX is a registered trademark of Don & Low Ltd Nonwovens.

Technical Specification

1 Description

1.1 The Daltex MultiTX Barrier Roof Tile Underlay is manufactured by thermal bonding a barrier membrane to a spunbond fabric to form a flexible sheet for unsupported applications.

1.2 The product has the nominal characteristics given in Table 1.

Table 1 Nominal characteristics

Characteristic (units)	Daltex MultiTX
Thickness (mm)	0.4
Weight per unit area (gm ⁻²)	116
Roll length (m) ⁽¹⁾	up to 50
Roll width (m) ⁽¹⁾	1.0
Roll weight (kg)	up to 6.5
Colour	grey

(1) Other roll widths and lengths are available.

1.3 Quality control checks are carried out on the incoming materials, during production and on the finished product. Quality control checks on the finished product include:

- weight
- water penetration
- tensile strength and elongation
- tear strength

2 Delivery and site handling

2.1 Rolls are delivered to site, individually wrapped in polyethylene. A technical leaflet bearing the product name is included with each roll and the BBA identification mark incorporating the number of this Certificate is shown on the leaflet. Labels with lot identifiers are attached to each roll for traceability.

2.2 The rolls should be stored flat on their sides, or on end on a smooth, clean, dry surface, under cover and protected from sunlight.

Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on the Daltex MultiTX Barrier Roof Tile Underlay.

Design Considerations

3 Use

The Daltex MultiTX Barrier Roof Tile Underlay is satisfactory for use as unsupported or supported on uninsulated timber sarking as an underlay in tiled and slated ventilated pitched roofs constructed in accordance with the relevant clauses of BS 5534 : 2003.

4 Weathertightness



4.1 Tests indicate that the Daltex MultiTX Barrier Roof Tile Underlay will resist the passage of water, wind-blown snow and dust into the interior of a building, under all conditions to be found in a roof constructed in accordance with the relevant clauses of BS 5534 : 2003.

4.2 The product should not be used for prolonged periods as temporary waterproof covering prior to the installation of slates or tiles. The period prior to the installation of the roof covering should be kept to a minimum.

5 Risk of condensation

5.1 The product should be regarded as an impermeable underlay when considering ventilation of a roof space.

5.2 For design purposes, the product's water vapour resistance may be taken as 57 MNsg⁻¹ and it should be regarded as Type 'HR' underlay as defined in BS 5534 : 2003 and BS 5250 : 2002.

5.3 Care should be taken to minimise the risk of water vapour coming into contact with cold parts of the roof construction. Factors to be considered and minimised include moisture diffusion through the ceiling, infiltration through unsealed openings/penetrations in the ceiling and services evaporating or venting moisture into cold spaces. Further guidance can be found in BS 5250 : 2002, Section 8.4, BS 5534 : 2003, Annex B and BRE report (BR 262 : 2002) *Thermal insulation : Avoiding risks*.

5.4 The risk of condensation is highest in new-build construction during the first heating period, where there is high moisture loading due to wet trades, such as in-situ cast concrete slabs or plaster. The risk of condensation diminishes as the building naturally dries out. See *BBA Information Bulletin No 1 – Roof Tile Underlays in Cold Roofs during the Drying-out Period*.

6 Wind loading

6.1 Project design wind speeds should be determined and wind uplift forces calculated, in accordance with BS 6399-2 : 1997.

6.2 When used in unsupported applications, draped, wind loading on the underlay should be calculated in accordance with BS 5534 : 2003, Section 5.5.2.7. For acceptable wind loads with specific batten spacings for the draped product, using a 25 mm deep tiling batten see section 14, Table for *Physical Properties – general*.

6.3 When used on timber sarking with counter battens, the product has adequate resistance to wind uplift forces.

7 Strength

The product will resist the loads associated with installation of the roof (see section 14, Table for *Physical properties – directional*).

8 Properties in relation to fire

8.1 The product will have similar properties in relation to fire to those of traditional polyethylene roof tile underlays.

8.2 When the product is used unsupported, there is a risk that fire can spread if the materials are accidentally ignited during maintenance works, eg by a roofer's or plumber's torch. As with all types of underlay, care should be taken during building and maintenance to avoid the material becoming ignited.

9 Durability



The product will be virtually unaffected by the normal conditions found in a roof space and will have a life comparable with that of traditional roof tile underlays, provided they are not exposed to sunlight for long periods (see section 10.4). Advice regarding exposure can be obtained from the Certificate holder.

Installation

10 General

10.1 The Daltex MultiTX Barrier Roof Tile Underlay must be installed and fixed in accordance with the Certificate holder's instructions, and the relevant recommendations of BS 5534 : 2003 and BS 8000-6 : 1990. Installation can be carried out under all conditions normal to roofing work.

10.2 Laps should be installed to shed water out and down the slope.

10.3 Overlaps must be provided with the minimum dimensions given in Table 2.

Table 2 Minimum overlaps

Roof pitch (°)	Horizontal lap (mm)		Vertical laps (mm)
	Not fully supported	Fully supported	
12.5 to 14	225	150	100
15 to 34	150	100	100
35+	100	75	100

10.4 In closed eaves constructions, eaves guards should be used to protect the product from sunlight and direct water into the gutter.

10.5 Hips and valleys should be covered with a 600 mm wide strip of the product.

11 Procedure

11.1 The product should not be laid directly onto insulated sarking board but can be laid on timber sarking in conjunction with counter battens.

11.2 The lining, when installed as a cold ventilated roof system, is fixed in the traditional method for roof tile underlays, ie draped between the rafters, or used in conjunction with counter battens.

11.3 When used in a hybrid warm roof specification, a ventilation gap of at least 20 mm between the insulation and the underlay should be allowed. A vapour control layer should be used on the underside of the insulation.

12 Repair

Damage to the underlay can be repaired easily prior to the installation of slates or tiles by replacement of the damaged areas, by patching and sealing correctly. Care should be taken to ensure that the watertightness of the roof is maintained.

13 Finishing

13.1 Detailing of abutments, verges and hips must be in accordance with the Certificate holder's instructions.

13.2 The tiling and slating must be carried out in accordance with the relevant clauses of BS 5534 : 2003, BS 8000-6 : 1990 and the Certificate holder's instructions, especially when using tightly-jointed slates or tiles.

14 Tests

Samples of the Daltex MultiTX Barrier Roof Tile Underlay were obtained from the Certificate holder for testing. The results of the tests carried out by, or on behalf of, the BBA are summarised in Tables 3 and 4.

Table 3 *Physical properties — directional*

Test (units)	Mean result	Method ⁽¹⁾
Tensile strength (N per 50 mm)		BS EN 12311-1
unaged		
long ⁽²⁾	227	
trans ⁽³⁾	153	
aged ⁽⁴⁾		
long ⁽²⁾	204	
trans ⁽³⁾	136	
wet strength ⁽⁵⁾		
long ⁽²⁾	228	
trans ⁽³⁾	157	
Elongation at break (%)		BS EN 12311-1
unaged		
long ⁽²⁾	43	
trans ⁽³⁾	73	
aged ⁽⁴⁾		
long ⁽²⁾	27	
trans ⁽³⁾	51	
wet strength ⁽⁵⁾		
long ⁽²⁾	39	
trans ⁽³⁾	70	
Tear resistance (nail) (N)		BS EN 12310-1
unaged		
long ⁽²⁾	198	
trans ⁽³⁾	262	

(1) The test documents are detailed in the *Bibliography*. Numbers in the table refer to sections/parts of the various documents.

(2) Longitudinal direction.

(3) Transverse direction.

(4) UVA aged for 336 hours at 50°C/heat aged for 90 days at (70±2)°C.

(5) Wet strength soak at 23°C for 24 hours.

Table 4 *Physical properties — general*

Test (units)	Mean result	Method ⁽¹⁾
Water vapour transmission at 25°C/75% RH (gm ⁻² day ⁻¹)	3.6	BS 3177
Vapour resistance (MNsg ⁻¹)	57	BS 3177
Slip resistance (coefficient of friction)		T1/10 ⁽²⁾
dry	0.9	
wet	0.6	
Resistance to water penetration		EN 1928 ⁽³⁾
unaged	Class W1	
aged ⁽⁴⁾	Class W1	
Resistance to streaming water unsupported	pass	MOAT 69 : 4.2.2
Mullen burst strength (kNm ⁻²)	565	BS 3137
Dimensional stability (%)		BS EN 1107-2
longitudinal	-0.58	
transverse	+0.13	
Resistance to wind loads (kPa) ⁽⁵⁾		MOAT 69 : 4.2.1
batten spacing 350 mm	0.5	
batten spacing 330 mm	0.5	
batten spacing 300 mm	1.0	
batten spacing 250 mm	2.0	
batten spacing 200 mm	2.5	

(1) The test documents are detailed in the *Bibliography*. Numbers in the table refer to sections/parts of the various documents.

(2) BBA Test Method.

(3) As modified in accordance with EN 13859-1 : 2005.

(4) UVA aged for 336 hours at 50°C/heat aged for 90 days at (70±2)°C.

(5) Test carried out using 25 mm thick battens and a 600 mm rafter spacing.

15 Investigations

The manufacturing process was assessed, including the method adopted for quality control, and details were obtained of the quality and composition of the materials used.

Bibliography

- BS 3137 : 1972 *Methods for determining the bursting strength of paper and board*
- BS 3177 : 1959 *Method for determining the permeability to water vapour of flexible sheet materials used for packaging*
- BS 5250 : 2002 *Code of practice for control of condensation in buildings*
- BS 5534 : 2003 *Code of practice for slating and tiling (including shingles)*
- BS 6399-2 : 1997 *Loading for buildings — Code of practice for wind loads*
- BS 8000-6 : 1990 *Workmanship on building sites — Code of practice for slating and tiling of roofs and claddings*
- BS EN 1107-2 : 2001 *Flexible sheets for waterproofing — Determination of dimension stability — Plastic and rubber sheets for roof waterproofing*
- BS EN 12310-1 : 2000 *Flexible sheets for waterproofing — Determination of resistance to tearing (nail shank) — Bitumen sheets for roof waterproofing*
- BS EN 12311-1 : 2000 *Flexible sheets for waterproofing — Determination of tensile properties — Bitumen sheets for roof waterproofing*
- EN 1928 : 2000 *Flexible sheets for waterproofing — Bitumen, plastic and rubber sheets for roof waterproofing — Determination of watertightness*
- EN 13859-1 : 2005 *Flexible sheets for waterproofing — Definitions and characteristics of underlays — Underlays for discontinuous roofing*
- MOAT No 69 : 2004 *UEAtc Technical Report for the Assessment of Discontinuous Roofing Underlay Systems*

16 Conditions

16.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is granted only to the company, firm or person named on the front page — no other company, firm or person may hold or claim any entitlement to this Certificate
- is valid only within the UK
- has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English law.

16.2 References in this Certificate to any Act of Parliament, Statutory Instrument, Directive or Regulation of the European Union, British, European or International Standard, Code of Practice, manufacturers' instructions or similar publication, are references to such publication in the form in which it was current at the date of this Certificate.

16.3 This Certificate will remain valid for an unlimited period provided that the product/system and the manufacture and/or fabrication including all related and relevant processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

16.4 In granting this Certificate, the BBA is not responsible for:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- individual installations of the product/system, including the nature, design, methods and workmanship of or related to the installation
- the actual works in which the product/system is installed, used and maintained, including the nature, design, methods and workmanship of such works.

16.5 Any information relating to the manufacture, supply, installation, use and maintenance of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used and maintained. It does not purport in any way to restate the requirements of the Health & Safety at Work etc Act 1974, or of any other statutory, common law or other duty which may exist at the date of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care. In granting this Certificate, the BBA does not accept responsibility to any person or body for any loss or damage, including personal injury, arising as a direct or indirect result of the manufacture, supply, installation, use and maintenance of this product/system.

